

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	411 c	7.41	11.80		0.95	y
2	710 5th	7.40	11.50		0.91	y
3	481 3rd	7.52	10.30	26	0.74	y
4	115 ne main	7.44	12.10		0.95	y
5	582 fir	7.41	10.90		0.79	y
6	360 maple	7.47	10.80		0.76	y
7	360 maple	7.49	10.90		0.74	y
8	411 c street	7.48	11.80		0.98	y
9	411 c street	7.42	15.70	27	0.59	y
10	391 yamhill	7.45	11.10		0.95	y
11	500 adams	7.42	11.70		0.87	y
12	360 maple	7.55	10.80		0.80	y
13	0	0.00	0.00		0.00	y
14	500 adams	7.40	9.10		0.91	y
15	500 adams	7.47	9.40		0.88	y
16	710 5th	7.40	8.50		0.80	y
17	481 3rd	7.35	10.40	24	0.92	y
18	582 fir	7.45	12.50		0.61	y
19	945 hill dr	7.31	17.30		0.84	y
20	360 maple	7.46	11.90		0.84	y
21	360 maple	7.35	12.40		0.86	y
22	411 c	7.33	12.50		0.95	y
23	481 3rd	7.34	9.70		0.92	y
24	710 5th	7.42	9.80	26	0.95	y
25	391 yamhill	7.47	14.80		0.90	y
26	115 ne main	7.35	9.90		0.92	y
27	360 maple	7.45	9.90		0.85	y
28	500 adams	7.33	10.30		0.97	y
29						y
30						y
31						y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Feb-21 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Riggs
Signature: *Justin R. Riggs*
Date: 3/2/2021

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405