

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	391 yamhill	7.57	19.2		0.68	y
2	360 maple	7.97	19.9		0.31	y
3	360 maple	7.85	18.7		0.33	y
4	115 ne main	7.69	18.3		0.61	y
5	1523 pioneer	7.55	17.5		0.59	y
6	500 adams	7.68	18.1		0.75	y
7	945 hill	7.72	18.6	47	0.29	y
8	582 fir	7.84	17.4		0.31	y
9	360 maple	7.91	19.8		0.2	y
10	360 maple	7.89	19.1		0.25	y
11	391 yamhill	7.65	17.5		0.78	y
12	411 c	7.79	14.4		0.83	y
13	360 maple	7.85	17.2		0.33	y
14	115 ne main	7.75	13.6		0.84	y
15	360 maple	7.75	13.5		0.39	y
16	360 maple	7.70	13.7		0.3	y
17	360 maple	7.73	13.6		0.35	y
18	360 maple	7.71	13.4		0.25	y
19	360 maple	7.80	12.9		0.38	y
20	411 c street	7.41	15.2	42	0.89	y
21	500 adams	7.41	15.2		0.66	y
22	710 5th	7.82	17.6		0.65	y
23	360 maple	7.78	17.4		0.35	y
24	360 maple	7.75	17.2		0.37	y
25	710 5th	7.79	16.7		0.51	y
26	411 c street	7.51	17.5	37	0.63	y
27	1523 pionner	7.57	14.3		0.4	y
28	945 hill dr	7.63	18.6		0.7	y
29	582 fir	7.58	17.8		0.48	y
30	360 maple	7.68	17.3		0.34	y
31	360 maple	7.78	17		0.43	y

Total N's 0


(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	
PWS ID:	41 0 0 9 5 3
System Name:	City of Willamina
Sample Period:	Oct-21
Sample Frequency:	Every 3 Years
Number of Distribution Samples Required:	2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Vaggis
Signature: 
Date: 11/1/2021

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Water System Name: City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sign: _____

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

4100953 City of Willamina					
Oct-21	Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
	jr	10/1/2021	0.68	1	391 yamhill
	jr	10/2/2021	0.31	1	360 maple
	jr	10/3/2021	0.33	1	360 maple
	jr	10/4/2021	0.61	1	115 ne main
	jr	10/5/2021	0.59	1	1523 pioneer
	jr	10/6/2021	0.75	1	500 adams
	jr	10/7/2021	0.29	1	945 hill dr
	jr	10/8/2021	0.31	1	582 fir
	jr	10/9/2021	0.2	1	360 maple
	jr	10/10/2021	0.25	1	360 maple
	jr	10/11/2021		toc/alkalinity	330 nw 6th
	jr	10/11/2021		toc	330 nw 6th
	jr	10/11/2021	0.78	106611	391 yamhill
	jr	10/12/2021	0.83	1	411 c street
	jr	10/13/2021	0.33	1	360 maple
	jr	10/14/2021	0.84	1	115 ne main
	al	10/15/2021	0.39	1	360 maple
	jr	10/16/2021	0.3	1	360 maple
	jr	10/17/2021	0.35	1	360 maple
	jr	10/18/2021	0.25	1	360 maple
	jr	10/18/2021		tthm haa5	360 maple 2 samples at post office
	jr	10/19/2021	0.38	1	360 maple
	jr	10/20/2021	0.89	1	411 ne c
	jr	10/21/2021	0.66	1	500 adams
	jr	10/22/2021	0.65	1	710 ne 5th
	jr	10/23/2021	0.35	1	360 maple
	jr	10/24/2021	0.37	1	360 maple
	jr	10/25/2021	0.51	1	710 5th
	jr	10/26/2021	0.63	1	411 c street
	jr	10/27/2021	0.4	1	1523 pioneer
	jr	10/28/2021	0.7	1	945 hill dr
	jr	10/29/2021	0.48	1	582 fir
	jr	10/30/2021	0.34	1	360 maple
	jr	10/31/2021	0.43	1	360 maple