

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.69	15.7		0.79	y
2	360 maple	7.77	14.8		0.40	y
3	411 c	7.37	14.5		1.10	y
4	710 5th	7.66	15.4	36	0.93	y
5	481 3rd	7.54	13.5		0.80	y
6	360 maple	7.68	16.5		0.41	y
7	360 maple	7.59	17.40		0.51	y
8	481 3rd	7.48	14.70		0.90	y
9	1523 pioneer	7.67	15.70		0.72	y
10	945 hill dr	7.51	17.80	30	0.89	y
11	500 adams	7.57	17.00		0.89	y
12	0	0.00	0.00		0.00	y
13	500 adams	7.43	14.00		0.83	y
14	360 maple	7.69	14.70		0.53	y
15	411 c	7.28	13.80		0.97	y
16	500 adams	7.29	14.60		0.98	y
17	360 maple	7.55	14.20		0.54	y
18	710 5th	7.44	15.00	28	0.83	y
19	582 fir	7.59	15.10		0.57	y
20	360 maple	7.55	14.70		0.50	y
21	500 adams	0.00	0.00		0.61	y
22	411 c	7.28	13.90		0.76	y
23	481 3rd	7.42	12.50		0.98	y
24	115 ne main	7.51	12.00	30	0.87	y
25	360 maple	7.61	15.10		0.52	y
26	360 maple	7.49	14.80		0.46	y
27	360 maple	7.44	14.30		0.61	y
28	360 maple	7.45	15.20		0.45	y
29	1523 pioneer	7.35	17.50		0.72	y
30	411 c	7.58	22.30		0.60	y
31						

Total N's

0

(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: <u>City of Willamina</u> Sample Period: <u>NOV 2021</u> Sample Frequency: <u>Every 3 Years</u> Number of Distribution Samples Required: <u>2</u>

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Biggs
 Signature: *Justin R. Biggs*
 Date: 12/11/2021

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

