

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.67	8.7		0.75	y
2	500 adams	7.40	9.8		0.87	y
3	411 c	7.46	9.6		0.81	y
4	500 adams	7.41	9.5		0.83	y
5	115 ne main	7.53	11.9	29	0.73	y
6	391 yamhill	7.43	11.8		0.84	y
7	411 ne c	7.31	12.9		0.8	y
8	360 maple	7.70	11.2		0.72	y
9	360 maple	7.72	13.5		0.67	y
10	500 adams	7.35	10.9		0.68	y
11	481 3rd	7.42	10.8		0.83	y
12	710 5th	7.49	11.6		0.81	y
13	391 yamhill	7.39	14.1	30	0.83	y
14	115 ne main	7.47	11.2		0.8	y
15	360 maple	7.66	11.4		0.75	y
16	360 maple	7.81	12.1		0.63	y
17	360 maple	7.71	12		0.65	y
18	582 fir	7.51	12.3		0.87	y
19	500 adams	7.60	12.1	30	0.88	y
20	411 c	7.44	15.9		0.81	y
21	481 3rd	7.50	14.8		0.8	y
22	360 maple	7.70	9.9		0.7	y
23	360 maple	7.68	12.7		0.75	y
24	710 5th	7.51	9.8		0.73	y
25	391 yamhill	7.55	16		0.76	y
26	115 ne main	7.52	9.1	29	0.6	y
27	500 adams	7.40	11.6		0.75	y
28	945 hill	7.62	12.1		0.64	y
29	360 maple	7.65	10.5		0.65	y
30	360 maple	7.77	9		0.58	y
31	500 adams	7.51	10.1		0.8	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Jan-22 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Kees
 Signature: *Justin R. Kees*
 Date: 2/17/2022

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

