

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.82	23.4		0.53	y
2	500 adams	7.69	24.5		0.72	y
3	411 c	7.75	23.2	40	0.96	y
4	710 5th	7.70	21.3		0.63	y
5	481 3rd	7.67	23.8		0.74	y
6	360 maple	7.65	21.4		0.51	y
7	360 maple	7.91	21.7		0.49	y
8	500 adams	7.73	21.8		0.51	y
9	391 yamhill	7.65	20.9		0.65	y
10	115 ne main	7.62	21.4		0.55	y
11	1523 pioneer	7.75	22.0		0.65	y
12	360 maple	7.98	22.1	44	0.54	y
13	360 maple	7.75	21.5		0.36	y
14	360 maple	7.80	22.1		0.34	y
15	945 hill	7.63	25.8		0.63	y
16	582 fir	7.71	24.1		0.21	y
17	391 yamhill	7.65	22.0		0.64	y
18	115 ne main	7.68	24.6		0.67	y
19	1523 pioneer	7.70	22.7	39	0.45	y
20	360 maple	7.93	22.7		0.28	y
21	360 maple	7.90	22.6		0.3	y
22	500 adams	7.74	24.0		0.88	y
23	411 ne c	7.59	23.6		0.78	y
24	481 3rd	7.56	23.3	40	0.68	y
25	710 5th	7.73	24.4		0.79	y
26	391 yamhill	7.69	22.8		0.64	y
27	360 maple	7.41	20.4		0.47	y
28	500 adams	7.54	20.7		0.55	y
29	115 ne main	7.76	24.3		0.89	y
30	500 adams	7.46	23.4		0.61	y
31	1523 pioneer	7.71	25.6		0.31	y

Total N's 0  
(NO = N = Excursions)

<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	PWS ID: <b>41</b> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">9</span> <span style="border: 1px solid black; padding: 0 2px;">5</span> <span style="border: 1px solid black; padding: 0 2px;">3</span> System Name: <b>City of Willamina</b> Sample Period: <u>August 2022</u> Sample Frequency: <b>Every 3 Years</b> Number of Distribution Samples Required: <span style="border: 1px solid black; padding: 0 10px;">2</span>

Number of excursions during this sample period: 0  
(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.  
Add Entry Point and Distribution Excursions to get total for sample period.

<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<span style="border: 1px solid black; padding: 2px 10px;">7.2</span>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name: Justin R Ross  
Signature: [Signature]  
Date: 9/1/2022

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:  
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

