Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	945 hill	7.71	22.5		0.64	y
2	582 fir	7.81	23.4	40	0.57	y
3	360 maple	7.65	22.5		0.36	y
4	360 maple	7.70	21.9		0.4	y
5	360 maple	7.75	22.2		0.39	y
6	500 adams	7.80	22.2		0.49	y
7	411 c	7.73	22.7	46	0.62	y
8	481 3rd	7.75	19.5		0.51	y
9	710 5th	7.68	22.7		0.75	y
10	360 maple	7.71	22.9		0.45	y
11	500 adams	7.49	22		0.39	y
12	360 maple	7.93	23.6		0.54	y
13	391 yamhill	7.65	22.8		0.65	y
14	115 ne main	7.73	20.3		0.86	y
15	115 ne main	7.66	21.3		0.94	y
16	1523 pioneer	7.63	23.1	43	0.55	y
17	360 maple	7.79	20.5		0.45	y
18	360 maple	7.80	20.8		0.42	y
19	500 adams	7.62	20.6		0.69	y
20	411 c	7.62	22.7		0.78	y
21	481 3rd	7.57	21.7		0.79	y
22	710 5th	7.79	20.6	45	0.73	y
23	391 yamhill	7.66	20.3		0.64	y
24	360 maple	7.43	18.9		0.64	y
25	500 adams	7.43	19.5		0.53	y
26	411 c	7.47	19.3		0.34	y
27	360 maple	7.48	19.4		0.77	y
28	500 adams	7.45	19.3		0.53	y
29	411 c	7.51	18.3		0.51	y
30	360 maple	7.66	20.3		0.64	y
31						
Total N's				0		

(NO = N = Excursions)

DISTRIBUTION

<<Have Minimums been met for this day?

PWS ID: 41 0 0 9 5 3

System Name: City of Willamina

Sample Period: Sep-22

Sample Frequency: Every 3 Years

Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk		*(Alkalinity)*
PO4		*(Orthophosphate)*
Other		( )

Print Name: Justin N Riggs

Signature: Justin N Riggs

Date: 10/3/2022

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Water System Name: City of Willamina ID: 4100953

Enter sample ID info in the table >>

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Sign:

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Month	Sep-22	4100953 City of Willamina		
Initial	**Date**	**Residual (mg/l)**	**Sample ID**	**Other Sample Location Description**
jr	9/1/2022	0.64	1	945 hill drive
jr	9/2/2022	0.57	1	582 fir
jr	9/3/2022	0.36	1	360 maple
jr	9/4/2022	0.4	1	360 maple
jr	9/5/2022	0.39	1	360 maple
jr	9/6/2022	0.49	1	500 adams
jr	9/7/2022	0.62	1	411 c
jr	9/8/2022	0.51	1	481 3rd
jr	9/9/2022	0.75	1	710 5th
jr	9/10/2022	0.78	1	710 5th
ba	9/11/2022	0.45	1	360 maple
jr	9/12/2022	0.39	1	500 adams
jr	9/13/2022	.65	1	391 yamhill
jr	9/14/2022	0.86	1	115 ne main
jr	9/15/2022	0.94	114808	115 ne main coliform
jr	9/16/2022	0.55	1	1523 pioneer
jr	9/17/2022	0.45	1	360 maple
jr	9/18/2022	0.42	1	360 maple
jr	9/19/2022	0.69	1	500 adams
jr	9/20/2022	0.78	1	411 c
jr	9/21/2022	0.79	1	481 3rd
jr	9/22/2022	0.73	1	710 5th
jr	9/23/2022	0.64	1	391 yamhill
ba	9/24/2022	0.53	1	360 maple
ba	9/25/2022	0.34	1	500 adams
ba	9/26/2022	0.77	1	411 c
ba	9/27/2022	0.53	1	360 maple
ba	9/28/2022	0.51	1	500 adams
ba	9/29/2022	0.77	1	411 c
jr	9/30/2022	0.48	1	360 maple