

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.86	13.3		0.77	y
2	360 maple	7.84	12.9		0.76	y
3	500 adams	7.67	12.2		1	y
4	411 c street	7.47	13		0.92	y
5	481 3rd	7.56	10.9		0.86	y
6	710 5th	7.52	11.2	31	0.9	y
7	391 yamhill	7.60	12.2		0.88	y
8	360 maple	7.72	11.3		0.81	y
9	500 adams	7.49	11.4		0.94	y
10	1523 pioneer	7.51	11		0.79	y
11	411 c	7.39	15.9		0.98	y
12	115 ne main	7.53	12.6		0.87	y
13	945 hill	7.41	10.6	29	0.57	y
14	582 fir	7.53	13.9		0.73	y
15	360 maple	7.86	11.4		0.82	y
16	360 maple	7.79	14.3		0.81	y
17	500 adams	7.59	12.3		0.88	y
18	411 c	7.42	15		0.89	y
19	481 3rd	7.54	12.4	26	0.92	y
20	710 5th	7.63	11.2		0.77	y
21	391 yamhill	7.34	11.4		0.93	y
22	360 maple	7.83	13.4		0.67	y
23	500 adams	7.58	12.2		0.58	y
24	1623 pionner	7.68	13.6		0.89	y
25	945 hill	7.55	17.5		0.9	y
26	582 fir	7.67	17	31	0.89	y
27	360 maple	7.82	13		0.78	y
28	500 adams	7.84	16.3		1.03	y
29	360 maple	7.89	16.2		0.87	y
30	360 maple	7.93	16.5		0.86	y
31						

Total N's

0

(NO = N = Excursions)

<<Have Minimums been met for this day?		DISTRIBUTION	
PWS ID:	41	0	0
System Name:	City of Willamina		
Sample Period:	April 2023		
Sample Frequency:	Every 3 Years		
Number of Distribution Samples Required:	2		

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Justin R Riggs
Signature: *Justin R Riggs*
Date: 5/17/2023

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

