

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	411 c	7.72	15.90		0.85	y
2	481 3rd	7.76	14.60		0.98	y
3	710 5th	7.85	15.30	31	0.98	y
4	391 yamhill	7.88	14.30		1	y
5	115 ne main	7.69	16.50		0.91	y
6	500 adams	7.73	13.20		0.87	y
7	360 maple	7.58	13.80		0.78	y
8	1523 pioneer	7.68	14.90		0.86	y
9	945 hill	7.66	15.50		0.9	y
10	582 fir	7.78	15.30		0.87	y
11	360 maple	8.04	12.10	33	0.75	y
12	411 c	8.00	11.50		0.8	y
13	360 maple	8.07	17.00		0.85	y
14	360 maple	8.01	17.20		0.86	y
15	481 3rd	7.61	19.40		0.9	y
16	710 5th	7.63	17.90		0.91	y
17	391 yamhill	7.69	19.20		0.83	y
18	115 ne main	7.59	18.80	35	0.92	y
19	1523 pioneer	7.65	14.70		0.67	y
20	360 maple	7.67	18.80		0.83	y
21	500 adams	7.61	16.20		0.7	y
22	945 hill	7.67	18.80		0.83	y
23	582 fir	7.90	17.60		0.61	y
24	360 maple	7.91	16.70		0.68	y
25	500 adams	7.84	17.80	36	0.75	y
26	360 maple	7.89	16.50		0.74	y
27	360 maple	7.90	16.70		0.75	y
28	360 maple	7.88	16.40		0.73	y
29	360 maple	7.89	16.20		0.76	y
30	411 c	7.67	19.70		0.77	y
31	710 5th	7.65	18.70		0.79	y

Total N's 0

(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: May-23 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	 (Alkalinity)
PO4	 (Orthophosphate)
Other	 ()

Print Name: Justin R. Riggs

Signature: *Justin R. Riggs*

Date: 6/12/2023

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.


Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Free Chlorine Residuals

Water System Name: City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sign: 

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Month	May-23	4100953 City of Willamina		
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
jr	5/1/2023	0.85	1	411 ne c street
jrr	5/2/2023	0.98	1	481 3rd
jrr	5/3/2023	0.98	1	710 5th
jrr	5/4/2023	1	1	391 yamhill
jrr	5/5/2023	0.91	1	115 ne main
ba	5/6/2023	0.87	1	500 adams
ba	5/7/2023	0.78	1	360 maple
jr	5/8/2023	0.86	1	1523 pioneer
jrr	5/9/2023	0.9	1	945 hill
jrr	5/10/2023	0.87	1	582 fir
jrr	5/10/2023	0.84	122618	1523 pioneer coliform
jrr	5/11/2023	0.75	1	360 maple
jrr	5/12/2023	0.8	1	411 c
jrr	5/13/2023	0.85	1	360 maple
jrr	5/14/2023	0.86	1	360 maple
jrr	5/15/2023	0.9	1	481 3rd
jrr	5/16/2023	0.91	1	710 5th
jrr	5/17/2023	0.83	1	391 yamhill
jrr	5/18/2023	0.92	1	115 ne main
jrr	5/19/2023	0.67	1	15423 pioneer
ba	5/20/2023	0.79	1	360 maple
ba	5/21/2023	0.7	1	500 adams
jr	5/22/2023	0.83	1	945 hill
jrr	5/23/2023	0.81	1	582 fir
jrr	5/24/2023	0.68	1	360 maple
jrr	5/25/2023	0.75	1	500 adams
jrr	5/26/2023	0.74	1	360 maple
jrr	5/27/2023	0.75	1	360 maple
jrr	5/28/2023	0.73	1	360 maple
jrr	5/29/2023	0.76	1	360 maple
jrr	5/30/2023	0.77	1	411 c
jrr	5/31/2023	0.79	1	710 5th