

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	481 3rd	7.66	18.2		0.77	y
2	391 yamhill	7.75	17.6	39	0.82	y
3	360 maple	8.09	17.7		0.71	y
4	500 adams	7.87	16.5		0.52	y
5	1523 pioneer	7.82	19.7		0.55	y
6	360 maple	8.05	18.8		0.67	y
7	945 hill	7.90	20.2	39	0.72	y
8	500 adams	7.87	18.1		0.93	y
9	411 c	7.67	17.5		0.95	y
10	360 maple	7.90	19		0.57	y
11	360 maple	8.00	19.1		0.58	y
12	391 yamhill	7.81	19.8		1.03	y
13	115 ne main	7.80	21		0.68	y
14	1523 pioneer	7.60	21.5		0.8	y
15	945 hill	7.69	19.1		0.72	y
16	582 fir	7.75	20.6	40	0.77	y
17	360 maple	7.79	18.6		0.5	y
18	500 adams	7.77	17.1		0.79	y
19	360 maple	8.05	17.9		0.75	y
20	411 c	7.55	18.1		1.01	y
21	710 5th	7.87	17.5	42	0.97	y
22	481 3rd	7.72	20.7		0.85	y
23	391 yamhill	7.80	20.1		0.88	y
24	360 maple	7.89	19.1		0.76	y
25	360 maple	7.99	19.2		0.79	y
26	115 ne main	7.61	7.65		0.91	y
27	391 yamhill	7.65	19.8		0.94	y
28	1523 pioneer	7.69	19.8	42	0.78	y
29	945 hill	7.76	20.2		0.91	y
30	582 fir	7.80	21.3		0.82	y
31						

Total N's 0

(NO = N = Excursions)

<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">9</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">3</span> <b>System Name:</b> City of Willamina <b>Sample Period:</b> Jun-23 <b>Sample Frequency:</b> Every 3 Years <b>Number of Distribution Samples Required:</b> 2

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<span style="border: 1px solid black; padding: 2px 10px;">7.2</span>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name: Justin R. Bess  
 Signature: [Signature]  
 Date: 7/6/2023

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:  
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

