

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.76	19.6		0.79	y
2	360 maple	8.00	19.9		0.66	y
3	500 adams	7.77	19.4		0.82	y
4	360 maple	7.98	19.7		0.68	y
5	360 maple	7.92	20.1		0.71	y
6	411 c	7.66	25.1		0.71	y
7	710 5th	7.75	21.5		0.66	y
8	360 maple	8.01	19.9		0.65	y
9	360 maple	7.98	19.6		0.67	y
10	411 c	7.67	24.3		0.81	y
11	582 fir	7.69	21.9		0.69	y
12	500 adams	7.79	21.8	43	0.84	y
13	481 3rd	7.68	27		0.55	y
14	710 5th	7.71	22.6		0.85	y
15	500 adams	7.65	23		0.65	y
16	360 maple	7.93	22.1		0.72	y
17	391 yamhill	7.80	23.3		0.93	y
18	115 ne main	7.65	23		0.88	y
19	411 c	7.57	22.6		0.86	y
20	115 ne main	7.60	24.1	45	0.94	y
21	1523 pioneer	7.65	25.2		0.9	y
22	360 maple	7.71	21.2		0.65	y
23	360 maple	7.65	20.5		0.63	y
24	945 hill	7.68	22.6		0.93	y
25	115 main	7.72	23.3		0.8	y
26	710 5th	7.80	25.1		0.92	y
27	481 3rd	7.67	21.9	45	1.02	y
28	391 yamhill	7.90	23.5		1.06	y
29	360 maple	7.98	22.9		0.74	y
30	500 adams	7.60	20.6		0.69	y
31	1523 pioneer	7.77	22.8		0.3	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Jul-23 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
Add Entry Point and Distribution Excursions to get total for sample period.

Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	 (Alkalinity)
PO4	 (Orthophosphate)
Other	 ()

Print Name: Justin R Ricess
 Signature: *Justin R Ricess*
 Date: 8/1/2023

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Water System Name: City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sign: *[Signature]*

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Month	Jul-23	4100953	City of Willamina	
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
ba	7/1/2023	0.79	1	500 adams
ba	7/2/2023	0.66	1	360 maple
ba	7/3/2023	0.82	1	500 adams
jrr	7/4/2023	0.68	1	360 maple
jrr	7/5/2023	0.71	1	360 maple
jrr	7/6/2023	0.71	1	411 c
jrr	7/7/2023	0.66	1	710 5th
jrr	7/8/2023	0.65	1	360 maple
jrr	7/9/2023	0.67	1	360 maple
jrr	7/10/2023	0.93	120582	945 hill dr coliform
jrr	7/10/2023	0.81	1	411 c
jrr	7/10/2023	toc&alk	ch-a	330 nw 6th
jrr	7/10/2023	toc&alk	wtp-a	330 nw 6th
jrr	7/11/2023	0.69	1	582 fir
jrr	7/12/2023	0.84	1	500 adams
jrr	7/13/2023	0.55	1	481 3rd
jrr	7/14/2023	0.85	1	710 5th
ba	7/15/2023	0.65	1	500 adams
ba	7/16/2023	0.72	1	360 maple
jr	7/17/2023	0.93	1	391 yamhill
jrr	7/18/2023	0.88	1	115 ne main
jrr	7/19/2023	0.86	1	411 c street
jrr	7/20/2023	0.94	1	115 ne main
jrr	7/21/2023	0.9	1	1523 pioneer
jrr	7/22/2023	0.65	1	360 maple
jrr	7/23/2023	0.63	1	360 maple
jr	7/24/2023	0.93	1	945 hill dr
jrr	7/25/2023	0.8	1	115 ne main
jrr	7/26/2023	0.92	1	710 5th
jrr	7/27/2023	1.02	1	481 3rd
jrr	7/28/2023	1.06	1	391 yamhill
ba	7/29/2023	0.74	1	360 maple
ba	7/30/2023	0.69	1	500 adams
jr	7/31/2023	0.3	1	1523 pioneer