

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	582 fir	7.73	22.7		0.9	y
2	500 adams	7.76	24.4		0.88	y
3	481 3rd	7.71	23.5	47	1	y
4	710 5th	7.74	23.6		0.95	y
5	360 maple	8.07	22.7		0.7	y
6	360 maple	8.04	22.4		0.78	y
7	391 yamhill	7.80	23		1.04	y
8	582 fir	7.75	23.2	47	0.79	y
9	360 maple	7.56	23.9		0.82	y
10	500 adams	7.73	23.4		0.93	y
11	411 c	7.67	22.4		1.05	y
12	360 maple	7.90	22.9		0.72	y
13	500 adams	7.76	22.7		0.99	y
14	710 5th	7.64	22.2		0.98	y
15	481 3rd	7.69	23		0.76	y
16	360 maple	7.89	25.1		0.71	y
17	391 yamhill	7.68	24.6	50	1.14	y
18	1523 pioneer	7.76	22.6		0.92	y
19	360 maple	7.85	21.8		0.69	y
20	360 maple	7.87	21.4		0.71	y
21	945 hill	7.66	23.6		0.78	y
22	582 fir	7.68	22		0.66	y
23	360 maple	7.62	20.4	40	0.41	y
24	500 adams	7.63	20.5		0.86	y
25	411 c	7.65	23.6		1.12	y
26	360 maple	7.99	21.7		0.77	y
27	500 adams	7.53	22.3		1.06	y
28	360 maple	7.85	22.5		0.82	y
29	500 adams	7.83	23		0.8	y
30	710 5th	7.70	24.1	44	0.8	y
31	481 3rd	7.56	21		0.98	y


Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Aug-23 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Hayes
Signature: 
Date: 9/5/2023

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Free Chlorine Residuals

Water System Name: City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Sign: 

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Month	Aug-23	4100953 City of Willamina		
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
jrr	8/1/2023	0.9	1	582 fir
jrr	8/2/2023	0.88	1	500 adams
jrr	8/3/2023	1	1	481 3rd
jrr	8/4/2023	0.95	1	710 5th
jrr	8/5/2023	0.7	1	360 maple
jrr	8/6/2023	0.78	1	360 maple
jr	8/7/2023	1.04	1	391 yamhill
jrr	8/8/2023	0.79	123768	582 fir coliform
jrr	8/9/2023	0.82	1	360 maple
jrr	8/10/2023	0.93	1	500 adams
jr	8/11/2023	1.05	1	411 c street
ba	8/12/2023	0.72	1	360 maple
ba	8/13/2023	0.99	1	500 adams
jrr	8/14/2023	0.98	1	710 5th
jrr	8/15/2023	0.76	1	481 3rd
jrr	8/16/2023	0.71	1	360 maple
jrr	8/17/2023	1.14	1	391 yamhill
jr	8/18/2023	0.92	1	1523 pioneer
jrr	8/19/2023	0.69	1	360 maple
jrr	8/20/2023	0.71	1	360 maple
jrr	8/21/2023	0.78	1	945 hill
jrr	8/22/2023	0.66	1	582 fir
jrr	8/23/2023	0.41	1	360 maple
jrr	8/24/2023	0.86	1	500 adams
jr	8/25/2023	1.12	1	411 c street
ba	8/26/2023	0.77	1	360 maple
ba	8/27/2023	1.06	1	500 adams
jrr	8/28/2023	0.82	1	360 maple
jrr	8/29/2023	0.8	1	500 adams
jrr	8/30/2023	0.8	1	710 5th
jrr	8/31/2023	0.98	1	481 3rd