

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.74	14.7		1.07	y
2	360 maple	7.84	13.4		0.93	y
3	360 maple	7.89	14.4		0.93	y
4	500 adams	7.65	14.5		1.37	y
5	411 c	7.38	17.1		1.3	y
6	115 ne main	7.41	15.2	25	1.28	y
7	1523 pioneer	7.51	14.1		1.01	y
8	582 fir	7.50	13.6		1.05	y
9	360 maple	7.67	14.3		0.98	y
10	360 maple	7.62	14.1		1.01	y
11	500 adams	7.54	14		1.13	y
12	411 c	7.39	13.2		1.06	y
13	710 5th	7.61	14.8	28	1.03	y
14	500 adams	7.55	13.6		1.01	y
15	481 3rd	7.66	13.1		1.07	y
16	360 maple	7.80	11.2		0.99	y
17	500 adams	7.62	12.2		1.11	y
18	391 yamhill	7.62	12.8		1.05	y
19	1523 pioneer	7.69	13.2		1.03	y
20	582 fir	7.57	13	29	0.96	y
21	500 adams	7.83	15		1.17	y
22	710 5th	7.5	14		1.23	y
23	360 maple	7.75	11.4		1.01	y
24	360 maple	7.65	11.3		0.98	y
25	360 maple	7.7	11.1		0.99	y
26	500 adams	7.71	13.4		0.98	y
27	411 c	7.33	14.1		1.06	y
28	500 adams	7.54	14.2	34	0.75	y
29	481 3rd	7.45	12.9		1.02	y
30	360 maple	7.64	13.5		1.02	y
31	360 maple	7.68	13.6		0.85	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Dec-23 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. H. 355
Signature: [Signature]
Date: 1/21/2024

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405