

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.40	14.7		1.15	y
2	500 adams	7.44	13.5	31	1.12	y
3	411 c	7.44	12.1		1.17	y
4	710 5th	7.52	13.5		1.1	y
5	710 5th	7.50	14		1.11	y
6	360 maple	7.65	13.8		1.09	y
7	360 maple	7.67	14.2		0.99	y
8	481 3rd	7.45	13.2		0.96	y
9	391 yamhill	7.52	15.5	29	0.87	y
10	115 ne main	7.28	12.6		0.7	y
11	582 fir	7.86	11.9		1.09	y
12	1523 pioneer	7.67	13.8		0.99	y
13	360 maple	7.69	11.5		1.04	y
14	500 adams	7.52	12.8		1.11	y
15	500 adams	7.62	12.3		1.38	y
16	360 maple	7.70	11.2		1.1	y
17	360 maple	7.65	9.8	28	1.02	y
18	411 c	7.46	10		1.23	y
19	710 5th	7.50	13.8		1.15	y
20	360 maple	7.65	11.8		1.09	y
21	360 maple	7.71	12.5		1.15	y
22	115 ne main	7.55	10.9		1.08	y
23	411 c	7.49	12.6		0.99	y
24	481 3rd	7.55	12.4		0.98	y
25	391 yamhill	7.55	12.3	27	0.96	y
26	115 ne main	7.61	12		0.98	y
27	500 adams	7.56	15.4		1.1	y
28	360 maple	7.69	13.5		1.04	y
29	153 pioneer	7.40	14.3		1.35	y
30	945 hill	7.44	18.1		1.51	y
31	582 fir	7.54	14.4		1.15	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Jan-24 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R Riggs
 Signature: *Justin R Riggs*
 Date: 2/1/24

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Water System Name: City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Sign: 

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Month	Jan-24	4100953 City of Willamina		
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
jr	1/1/2024	1.15	1	500 adams
jrr	1/2/2024	1.12	1	500 adams
jr	1/3/2024	1.17	1	411 c
jrr	1/4/2024	1.1	1	710 5th
jrr	1/5/2024	1.11	1	710 5th
jrr	1/6/2024	1.09	1	360 maple
jrr	1/7/2024	0.99	1	360 maple
jrr	1/8/2024	0.96	1	481 3rd
jrr	1/9/2024	0.87	1	391 yamhill
jrr	1/10/2024	0.7	1	115 main
jrr	1/11/2024	1.09	1	582 fir
jrr	1/12/2024	0.99	1	1523 pioneer
ba	1/13/2024	1.04	1	360 maple
ba	1/14/2024	1.11	1	500 adams
ba	1/15/2024	1.38	1	500 adams
jrr	1/16/2024	1.1	1	360 maple
jrr	1/17/2024	1.02	1	360 maple
jrr	1/18/2024	1.23	1	411 c
jrr	1/19/2024	1.15	1	710 5th
jrr	1/20/2024	1.09	1	360 maple
jrr	1/21/2024	1.15	1	360 maple
jrr	1/22/2024	1.08	1	115 ne main
jrr	1/23/2024	0.99	121673	411 c coliform
jrr	1/23/2024		toc	wtp-a
jrr	1/23/2024		toc & alk	ch-a
jrr	1/24/2024	0.98	1	710 5th
jrr	1/25/2024	0.96	1	391 yamhill
jrr	1/26/2024	0.98	1	115 ne main
jr	1/27/2024	1.1	1	500 adams
jr	1/28/2024	1.04	1	360 maple
jrr	1/29/2024	1.35	1	1523 pioneer
jrr	1/30/2024	1.51	1	945 hill dr
jrr	1/31/2024	1.15	1	582 fir