

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.58	13.50		1.22	y
2	500 adams	7.62	12.90		1.09	y
3	360 maple	7.61	12.30		1.39	y
4	360 maple	7.50	12.90		1.45	y
5	411 c	7.57	13.30		1.55	y
6	710 5th	7.57	12.90		1.52	y
7	481 3rd	7.57	14.50		1.43	y
8	391 yamhill	7.56	14.80	34	1.18	y
9	500 adams	7.65	13.60		1.25	y
10	360 maple	7.78	13.40		1.28	y
11	500 adams	7.62	12.40		1.15	y
12	1523 pioneer	7.59	16.60		1.09	y
13	500 adams	7.67	13.00		1.10	y
14	945 hill dr	7.59	16.20		1.02	y
15	582 fir	7.43	12.10	33	1.09	y
16	411 c	7.56	16.20		1.04	y
17	360 maple	7.72	14.10		0.92	y
18	360 maple	7.70	13.90		0.90	y
19	360 maple	7.71	14.00		0.95	y
20	360 maple	7.77	14.20		0.93	y
21	500 adams	7.61	13.70	29	1.00	y
22	411 c	7.55	16.70		1.07	y
23	710 5th	7.49	15.10		1.01	y
24	360 maple	7.58	14.50		0.97	y
25	360 maple	7.70	12.60		0.99	y
26	481 3rd	7.52	14.00		0.97	y
27	710 5th	7.63	14.40		1.05	y
28	115 ne main	7.57	13.90	31	1.02	y
29	1523 pioneer	7.62	14.20		0.92	y
30						
31						


Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Feb-24 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin N. High
Signature: 
Date: 3/1/24

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

