

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.58	14.2		0.71	y
2	411 c	7.55	16		0.69	y
3	481 3rd	7.54	15	30	1.13	y
4	710 5th	7.66	14.4		1.07	y
5	391 yamhill	7.61	14.9		1.15	y
6	360 maple	7.68	13.1		1.01	y
7	500 adams	7.77	13.2		1.16	y
8	360 maple	7.68	14.4		1.02	y
9	391 yamhill	7.65	16.1		1.12	y
10	115 ne main	7.30	16.4	31	0.64	y
11	1523 pioneer	7.64	15.9		0.85	y
12	945 hill dr	7.51	18.1		1.01	y
13	360 maple	7.65	13.5		1.04	y
14	360 maple	7.68	13.2		1.01	y
15	500 adams	7.63	14.8		0.86	y
16	582 fir	7.55	14.6		1.02	y
17	411 c	7.66	16.8		1.03	y
18	710 5th	7.75	16.7	34	1	y
19	481 3rd	7.58	15.1		1	y
20	360 maple	7.82	15.7		1.01	y
21	360 maple	7.75	16		0.98	y
22	391 yamhill	7.68	15		0.9	y
23	115 ne main	7.73	15.5		1.06	y
24	1523 pioneer	7.68	16.1	33	0.92	y
25	945 hill dr	7.64	18.2		0.97	y
26	582 fir	7.63	18.8		0.91	y
27	360 maple	7.75	15.2		1.01	y
28	360 maple	7.72	14.8		1.05	y
29	500 adams	7.61	17.9		0.95	y
30	411 c	7.65	14.5		0.98	y
31						y

Total N's 0  
(NO = N = Excursions)

<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">9</span> <span style="border: 1px solid black; padding: 0 2px;">5</span> <span style="border: 1px solid black; padding: 0 2px;">3</span> <b>System Name:</b> City of Willamina <b>Sample Period:</b> Apr-24 <b>Sample Frequency:</b> Every 3 Years <b>Number of Distribution Samples Required:</b> 2

Number of excursions during this sample period: 0  
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.  
 Add Entry Point and Distribution Excursions to get total for sample period.

<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<span style="border: 1px solid black; padding: 2px 10px;">7.2</span>
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name: Justin R. Riggs  
 Signature: [Signature]  
 Date: 5/2/24

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:  
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

