Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2 0.95	Y/N	
1	360 maple	7.84	16.2			у	
2	500 adams				0.9	у	
3	115 main	7.80	17.5	36	0.95	у	
4	582 fir	7.79	19.5		0.95	у	
5	945 hill dr	7.78	19.4		0.82	У	
6	500 adams	7.84	19.7		0.68	у	
7	411 c	7.58	20.8		0.93	у	
8	360 maple	7.74	18.5		0.92	У	
9	360 maple	7.90	19.2		0.94	у	
10	710 5th	7.79	18.3		0.93	у	
11	481 3rd	7.54	19.2	_	0.78	У	
12	391 yamhill	7.61	17.5	38	0.93	У	
13	115 main	7.57	19		1.16	У	
14	4 1523 pioneer		17.6		0.73	У	
15	5 360 maple		18.1		0.82	У	
16	360 maple	7.91	16.8		0.91	У	
17	7 360 maple		16.2		0.92	У	
18	945 hill dr	7.72	205		0.85	у	
19	582 fir	7.65	19.8		0.87	у	
20	360 maple	7.67	18.7		0.83	У	
21	500 adams	7.73	21.1	39	1.09	У	
22	360 maple	and the second			0.98	у	
23	500 adams 7.5		19.8		1.01	у	
24	115 ne main 7.5		19.6		1.06	у	
25	411 c	7.68 17.3		1.01	У		
26	710 5th	710 5th 7.84 20.9 43		43	1.05	У	
27	481 3rd 7.		20.4		0.95	У	
28	481 3rd	7.6	19.8		0.92	У	
29	500 adams	7.85	20		0.91	У	
30	360 maple	7.90	19.3		0.69	у	
31							
Total N	s			0			

< <have< th=""><th colspan="8">DISTRIBUTION</th></have<>	DISTRIBUTION							
Minimums been met for	PWS ID:	41	0	0	9	5	3	
this day?	System Name:	City of Willamina						
	Sample Period:			Jı	ın-2	24		
Sam	ple Frequency:	Ev	ery 3	Yea	ars			
Number of I	Distribution Sample	es Requi	ired:			1	2	

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OH	A use o	only	
Ν	/linim	um Water Quality	y I
F	Param	eters as set by C	AHA
pH	7.2	7	
Alk	30	(Alkalinity)	
PO4		(Orthophosphate)	
Other		()
Print I	Name	Jaskn	n 1665
Signa	ture:	OTH	-1150
Date:		171312	Y

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

(NO = N = Excursions)

Send to DWS within 10 days after end of the sampling period to: OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Free Chlorine Residuals

Water System Name:

•••

1

City of Willamina

ID: 4100953

•

1

nter samp	ole ID info in the ta	ble >>	Sample ID	Sample Location Description
ĺ	In la	11.5	1	coliform sample sites used for rotation
ign:	ford	Mge		
11		/		
Aax Chlor		éd = 4.0 mg/l Enter up	-	
	to 200 results			
Month	Jun-24		City of Willamin	
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
ba	6/1/2024	0.95	1	360 maple
ba	6/2/2024	0.9	1	500 adams
jrr	6/3/2024	0.94	161731	coliform 1523 pioneer
jrr	6/3/2024	0.95	1	115 ne main
jrr	6/4/2024	0.95	1	582 fir
jrr	6/5/2024	0.82	1	945 hill dr
jrr	6/4/2024	0.68	1	500 adams
jrr jrr	6/7/2024 6/8/2024	0.93	1	411 c street 360 maple
jrr	6/9/2024	0.92	1	360 maple
jrr	6/10/2024	0.94	1	710 5th
jrr	6/11/2024	0.33	1	481 3rd
jrr	6/12/2024	0.93	1	391 yamhill
jrr	6/13/2024	1.16	1	115 main
jrr	6/14/2024	0.73	1	1523 pioneer
jr	6/15/2024	0.82	1	360 maple
jr	6/16/2024	0.91	1	360 maple
jrr	6/17/2024	0.92	1	360 maple
jrr	6/18/2024	0.85	1	945 hill dr
jrr	6/19/2024	0.87	1	582 fir
jrr	6/20/2024	0.83	1	360 maple
jrr	6/21/2024	1.09	1	500 adams
jrr	6/22/2024	0.98	1	360 maple
jrr	6/23/2024	1.01	1	500 adams
jrr	6/24/2024	1.06	1	115 ne main
jrr	6/25/2024	1.01	1	411 c street
jrr	6/26/2024	1.05	1	710 5th
jrr	6/27/2024	0.95	1	481 3rd
jrr	6/28/2024	0.92	1	481 3rd
ba	6/29/2024	0.91	1	500 adams
ba	6/30/2024	0.69	1	360 maple
	2			
			<u> </u>	
			<u></u>	
	2010-2010-2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 2010 - 201			