Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	CI2	Y/N
1	500 adams	7.85	20		1.17	у
2	360 maple	7.90	19.3		1.02	у
3	481 3rd	7.69	20.4	41	1.12	у
4	360 maple	7.87	19.8		1.14	у
5	360 maple	7.65	21.7		1.07	У
6	360 maple	7.67	22		0.99	у
7	360 maple	7.62	22.2		0.95	у
8	391 yamhill	7.69	22.7		0.93	у
9	1523 pioneer	7.30	28.6		1.09	у
10	945 hill	7.79	24	43	1.12	у
11	582 fir	7.76	25		1.06	у
12	500 adams	7.73	22.4		1.04	у
13	360 maple	7.86	21.4		0.96	У
14	360 maple	7.90	21.7		1.01	у
15	411 c	7.65	25.1		0.97	У
16	710 5th	7.70	22	40	0.99	у
17	481 3rd	7.60	21.9		0.96	у
18	391 yamhill	7.70	24.7		0.99	у
19	360 maple	7.71	21.4		0.99	у
20	360 maple	7.88	21.9		1	у
21	360 maple	7.85	22		0.96	у
22	582 fir	7.76	23.1		1.1	у
23	945 hill	7.70	20.9		1.17	у
24	500 adams	7.65	22.8	42	1.13	У
25	411 c	7.68	22.4		1.11	у
26	411 c	7.63	22.7		1.18	У
27	500 adams	7.71	21.5		1.15	у
28	360 maple	7.92	20.4		1.17	у
29	710 5th	7.87	23		1.3	у
30	500 adams	7.66	22.9		1.26	У
31	481 3rd	7.66	23.8		1.18	у
Total N	's			0		·

< <have< th=""><th colspan="8">DISTRIBUTION</th></have<>	DISTRIBUTION							
Minimums been met for	PWS ID:	41	0	0	9	5	3	
this day?	System Name:	City of Willamina						
	Sample Period:	1.00 MA (1 - 1008		J	ul-2	4		
Sam	ple Frequency:	Ev	ery 3	Yea	ars			
Number of D	Distribution Sample	es Requi	ired:			- :	2	

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

	/linim	only um Water Quality eters as set by OHA	*
рН	7.2		
Alk		(Alkalinity)	
PO4		(Orthophosphate)	
Other			
14. 1.		-	

Print Name: _ Signature:

Date:

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

(NO = N = Excursions)

Send to DWS within 10 days after end of the sampling period to: OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Water System Name:

City of Willamina

ID: 4100953

Enter samp	le ID info in the tab	le >> [Sample ID	Sample Location Description
Sign:	hold 1	114.	1	coliform sample sites used for rotation
7	7-0-0	199		
Max Chlori	ne Residual Allowe to 200 results l	d = 4.0 mg/l Enter up		
Month	Jul-24	L	City of Willamin	a
			, : · · · · · · · · · · · · · · · · ·	·

	to 200 results	s below		
Month	Jul-24	7	City of Willamir	na
Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
jrr	7/1/2024	0.98	1	500 adams
jrr	7/2/2024	1.02	1	710 5th
jrr	7/3/2024	1.01	1	481 3rd
jrr	7/4/2024	0.81	1	360 maple
jrr	7/5/2024	0.74	1	360 maple
jrr	7/624	0.76	1	360 maple
jrr	7/7/2024	0.77	1	360 maple
jrr	7/8/2024	0.76	1	391 yamhill
jrr	7/8/2024	0.77	133767	582 fir coliform
jrr	7/8/2024		toc&alk	ch-a
jrr	7/8/2024		toc	wtp-a
jrr	7/9/2024	0.52	1	1523 pioneer
jrr	7/10/2024	0.85	1	945 hill
jrr	7/11/2024	0.8	1	582 fir
jrr	7/12/2024	0.94	1	500 adams
jr	7/13/2024	0.96	1	360 maple
jr	7/14/2024	1.01	1	360 maple
jrr	7/15/2024	0.68	, 1	411 c
jrr	7/16/2024	0.73	1	710 5th
jrr	7/17/2024	0.58	1	481 3rd .
jrr	7/18/2024	0.79	1	391 yamhill
jrr	7/19/2024	0.8	1	360 maple
jrr	7/20/2024	0.71	1	360 maple
jrr	7/21/2024	0.75	1	360 maple
jrr	7/22/2024	0.71	1	582 fir
jrr	7/23/2024	0.96	1	945 hill'
jrr	7/24/2024	0.88	1	500 adams
jrr	7/25/2024	0.97	1	411 c
jrr	7/26/2024	0.98	1	411 c
ba	7/27/2024	0.89	1	500 adams
ba	7/28/2024	0.76	1	360 maple
jrr	7/29/2024	1.14	1	710 5th
jrr	7/30/2024	0.91	1	500 adams
jrr	7/31/2024	1.01	1	481 3rd
	^			
				<u> </u>