

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.65	20.4		0.76	y
2	360 maple	7.70	20.6		0.74	y
3	500 adams	7.80	20.9		0.83	y
4	710 5th	7.86	20.1		0.83	y
5	481 3rd	7.82	20.5	43	0.99	y
6	391 yamhill	7.68	21.6		0.62	y
7	360 maple	7.88	21.1		0.48	y
8	360 maple	7.79	21		0.6	y
9	1523 pioneer	7.79	21		0.61	y
10	945 hill dr	7.90	20.8	47	0.89	y
11	582 fir	7.68	20.6		0.68	y
12	500 adams	7.75	20.5		0.9	y
13	411 c	7.66	19.3		1.06	y
14	360 maple	7.97	19.8		0.35	y
15	360 maple	8.02	19.2		0.24	y
16	710 ne 5th	7.89	18.4		0.95	y
17	500 adams	7.68	19.1		0.99	y
18	411 c	7.60	18.8	48	1.06	y
19	710 5th	7.75	17.6		0.96	y
20	481 3rd	7.67	18.2		0.86	y
21	360 maple	7.99	16.9		0.54	y
22	500 adams	7.76	17.4		0.98	y
23	391 yamhill	7.78	18.4		1.19	y
24	481 3rd	7.79	18.6		1	y
25	1523 pioneer	7.75	19.5	48	0.9	y
26	500 adams	7.63	18		0.77	y
27	411 c	7.62	18.8		0.89	y
28	360 maple	7.82	18.1		0.66	y
29	360 maple	7.89	17.7		0.65	y
30	582 fir	7.69	16.3		0.76	y
31	0	0.00	0		0	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: <u>City of Willamina</u> Sample Period: <u>Sep-24</u> Sample Frequency: <u>Every 3 Years</u> Number of Distribution Samples Required: <u>2</u>

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Ribbs
 Signature: [Signature]
 Date: 10/3/24

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

