

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.74	20.4		0.88	y
2	710 5th	7.76	19	46	0.8	y
3	481 3rd	7.61	18		0.93	y
4	391 yamhill	7.69	19.7		0.97	y
5	360 maple	7.97	19.7		0.59	y
6	360 maple	8.00	19.7		0.66	y
7	1523 pioneer	7.75	22.6		0.83	y
8	945 hill	7.72	20.4	52	0.83	y
9	582 fir	7.83	20.3		0.72	y
10	360 maple	7.98	21.9		0.72	y
11	500 adams	7.73	18.9		0.9	y
12	411 c	7.65	18.6		0.95	y
13	360 maple	7.89	18.5		0.65	y
14	360 maple	7.86	18.6		0.64	y
15	710 5th	7.71	19		0.88	y
16	481 3rd	7.50	18.1	52	0.94	y
17	391 yamhill	7.78	18.7		0.72	y
18	1523 pioneer	7.70	17.9		0.69	y
19	360 maple	7.94	18.3		0.55	y
20	360 maple	7.84	18.6		0.52	y
21	500 adams	7.69	19.2		0.73	y
22	411 c	7.64	18.4		0.77	y
23	710 5th	7.64	19.4		0.95	y
24	710 5th	7.64	19.2	47	0.95	y
25	500 adams	7.78	16.7		0.7	y
26	360 maple	7.81	18.5		0.54	y
27	360 maple	7.85	18.2		0.51	y
28	391 yamhill	7.49	16.3	49	0.64	y
29	411 c	7.67	15.3		0.97	y
30	115 main	7.49	16.6	46	0.64	y
31	1523 pioneer	7.69	16.5		0.59	y

Total N's 0
(NO = N = Excursions)

<<Have		DISTRIBUTION					
Minimums	PWS ID:	41	0	0	9	5	3
been met for	System Name:	City of Willamina					
this day?	Sample Period:	Oct-24					
	Sample Frequency:	Every 3 Years					
	Number of Distribution Samples Required:	2					

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only		Minimum Water Quality Parameters as set by OHA	
pH	7.2		
Alk	30	(Alkalinity)	
PO4		(Orthophosphate)	
Other		()	

Print Name: Justin R Ribos
Signature: *Justin R Ribos*
Date: 11/12/24


*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Free Chlorine Residuals

Water System Name: City of Willamina ID: 4100953

Enter sample ID info in the table >>

Sign: 

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Month: Oct-24 ID: 4100953 City of Willamina

Initial	Date	Residual (mg/l)	Sample ID	Other Sample Location Description
jrr	10/1/2024	0.8	1	500 adams
jrr	10/2/2021	0.8	1	710 5th
jrr	10/3/2024	0.93	1	481 3rd
jrr	10/4/2024	0.97	1	391 yamhill
jr	10/5/2024	0.89	1	360 maple
jr	10/6/2024	0.66	1	360 maple
jrr	10/7/2024	0.83	1	1523 pioneer
jrr	10/7/2024	0.99	134144	411 c street coliform
jrr	10/7/2024	ch-a	toc&alk	330 nw 6th
jrr	10/7/2024	wtp-a	toc	330 nw 6th
jrr	10/7/2024	dist-a	haa5 tthm	360 maple
jrr	10/7/2024	dist-a	haa5 tthm	360 maple
jrr	10/8/2024	0.83	1	945 hill
jrr	10/9/2024	0.72	1	582 fir
jrr	10/10/2024	0.51	1	360 maple
jrr	10/11/2024	0.9	1	500 adams
jrr	10/12/2024	0.95	1	411 c street
jrr	10/13/2024	0.65	1	360 maple
jrr	10/14/2024	0.64	1	360 maple
jrr	10/15/2024	0.88	1	710 5th
jrr	10/16/2024	0.94	1	481 3rd
jrr	10/17/2024	0.72	1	391 yamhill
jrr	10/18/2024	0.69	1	1523 pioneer
jrr	10/19/2024	0.55	1	360 maple
jrr	10/20/2024	0.52	1	360 maple
jrr	10/21/2024	0.73	1	500 adams
jrr	10/22/2024	0.77	1	411 c
jrr	10/23/2024	0.95	1	710 5th
jrr	10/24/2024	0.79	1	481 3rd
jrr	10/25/2024	0.7	1	500 adams
jrr	10/26/2024	0.54	1	360 maple
jrr	10/27/2024	0.51	1	360 maple
jrr	10/28/2024	0.64	1	391 yamhill
jr	10/29/2024	0.97	1	411 ne c
jrr	10/30/2024	0.64	1	115 ne main
jrr	10/31/2024	0.59	1	1523 pioneer