

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	9445 hill	7.85	17.9		0.53	y
2	360 maple	8.09	15.5		0.42	y
3	500 adams	7.85	15.5		0.89	y
4	582 fir	7.78	15.2		0.56	y
5	360 maple	8.00	17.4		0.47	y
6	500 adams	7.63	15		0.88	y
7	411 c	8.02	17.6	38	1.08	y
8	710 5th	7.85	18.4		0.8	y
9	360 maple	7.89	16.2		0.53	y
10	360 maple	7.92	16.4		0.48	y
11	360 maple	7.69	16.6		0.55	y
12	411 c	7.79	15.3	40	0.92	y
13	481 3rd	7.74	15.2		0.8	y
14	710 5th	7.67	15.5		0.72	y
15	391 yamhill	8.17	16.2		0.76	y
16	360 maple	7.68	13.2		0.52	y
17	500 adams	7.59	13.8		1.21	y
18	1523 pioneer	7.93	15.7		0.97	y
19	360 maple	7.90	14.8		0.71	y
20	360 maple	7.68	14.4		0.72	y
21	582 fir	7.47	15.4	38	0.57	y
22	500 adams	7.91	15.5		1.05	y
23	360 maple	7.87	15.2		0.77	y
24	360 maple	7.57	15		0.76	y
25	411 c	7.63	16.9	34	1.01	y
26	391 yamhill	7.62	15		1.01	y
27	411 c	7.68	13.1		1	y
28	360 maple	7.88	12.7		0.83	y
29	360 maple	7.73	12.5		0.78	y
30	360 maple	7.76	11.7		0.81	y
31						

Total N's

0

(NO = N = Excursions)

<<Have Minimums been met for this day?		<b>DISTRIBUTION</b>	
<b>PWS ID:</b>	41	0	0
<b>System Name:</b>	City of Willamina		
<b>Sample Period:</b>	Nov-24		
<b>Sample Frequency:</b>	Every 3 Years		
<b>Number of Distribution Samples Required:</b>	2		

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only	
<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name:

Justin N Riggs

Signature:

Justin N Riggs

Date:

12/3/24

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

