

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.76	13		0.79	y
2	500 adams	7.47	13.213		1.02	y
3	710 5th	7.87	13.9		1.02	y
4	481 3rd	7.70	10.5	36	0.93	y
5	391 yamhill	7.73	13.6		1.01	y
6	1523 pioneer	7.75	12.5		0.8	y
7	360 nmaple	7.98	14.5		0.89	y
8	360 maple	8.01	14.7		0.9	y
9	945 hill	7.63	13.7		0.92	y
10	582 fir	7.72	13.5		0.94	y
11	500 adams	7.60	15.2	35	1.04	y
12	411 c	7.62	12.9		1.13	y
13	710 5th	7.81	13.1		1.12	y
14	360 maple	8.04	12.6		0.89	y
15	500 adams	7.75	11.6		0.97	y
16	481 3rd	7.67	12.4		0.95	y
17	360 maple	7.76	13.9		0.87	y
18	710 5th	7.51	14.2		0.83	y
19	360 maple	7.80	13.5		0.89	y
20	1523 pioneer	7.56	15.5	33	0.86	y
21	360 maple	7.76	13.8		0.9	y
22	360 maple	7.8	14		0.91	y
23	945 hill dr	7.73	14.5	31	0.92	y
24	582 fir	7.71	14.1		0.87	y
25	360 maple	7.89	13.3		0.96	y
26	411 c	7.7	16.9		0.86	y
27	500 adams	7.77	13.4		0.98	y
28	360 maple	7.84	14.2		0.83	y
29	360 maple	7.84	12.8		0.74	y
30	710 5th	7.94	14.9	39	1.06	y
31	481 3rd	7.71	12.2		0.94	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 00953 System Name: City of Willamina Sample Period: Dec-24 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
 (Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
 Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Riggs
Signature: *Justin R. Riggs*
Date: 1/2/25

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

