

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.85	14.2		0.85	y
2	391 yamhill	7.80	14.5		1.04	y
3	500 adams	7.82	15.1		1.08	y
4	360 maple	7.70	14		0.86	y
5	360 maple	7.74	14.2		0.88	y
6	411 c street	7.49	15		1.17	y
7	710 5th	7.68	13.7		1.04	y
8	481 3rd	7.57	13.1	30	1	y
9	945 hill dr	7.61	15.4		1.12	y
10	500 adams	7.66	13.9		0.91	y
11	360 maple	8.00	12		1.02	y
12	500 adams	7.81	12.8		1.06	y
13	360 maple	7.71	11.8		0.82	y
14	710 5th	7.62	10.7		1.04	y
15	481 3rd	7.74	13.7		1.11	y
16	391 yamhill	7.72	12.8	33	0.95	y
17	1523 pioneer	7.65	11.8		0.96	y
18	360 maple	7.70	10.5		1.01	y
19	360 maple	7.65	11.1		0.98	y
20	360 maple	7.69	10.7		1.05	y
21	500 adams	7.62	9.8		1.05	y
22	115 main	7.51	9.9		0.87	y
23	411 c street	7.57	11.6	35	1.15	y
24	500 adams	7.58	10.5		1.16	y
25	360 maple	8.02	10.4		1.16	y
26	360 maple	8.03	9.8		1.12	y
27	710 5th	7.68	12.7		0.88	y
28	411 ne 3rd	7.61	7.6		1.07	y
29	115 ne main	7.62	8.4	35	1.13	y
30	1523 pioneer	7.77	12.3		1.06	y
31	500 adams	7.67	9.7		0.95	y

Total N's

0

(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Jan-25 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Justin R. Riggs
Signature: *[Signature]*
Date: 2/4/25

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

ID: 4100953

Enter sample ID info in the table >>

Sign:

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

[illegible]