

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	8.03	13		0.99	y
2	360 maple	7.98	12.6		0.96	y
3	582 fir	7.98	11.9		0.87	y
4	500 adams	7.69	10.6		1.01	y
5	115 ne main	7.63	9.9	33	1.08	y
6	1523 pioneer	7.50	12.1		1.03	y
7	945 hill dr	7.63	13.8		0.97	y
8	360 maple	8.02	9.3		0.86	y
9	500 adams	7.87	10.7		1.14	y
10	582 fir	7.68	10.4		0.98	y
11	411 c	7.57	10.4		0.9	y
12	411 c	7.53	9.8		0.95	y
13	360 maple	7.85	10.1	34	0.88	y
14	710 5th	7.71	8.5		0.91	y
15	360 maple	7.91	9.1		0.9	y
16	360 maple	7.90	8.9		0.89	y
17	360 maple	7.85	9.2		0.92	y
18	500 adams	7.85	12.8		0.99	y
19	411 c street	7.62	14.5		1.05	y
20	481 3rd	7.57	11.1		1.03	y
21	710 5th	7.66	14	32	1.12	y
22	360 maple	7.86	12.8		0.97	y
23	360 maple	7.87	12.2		0.93	y
24	391 yamhill	7.81	14.6		1.02	y
25	411 c	7.62	11.9		1.06	y
26	710 5th	7.71	13.2		1.01	y
27	500 adams	7.85	12.7	32	0.99	y
28	500 adams	7.75	15.3		1.01	y
29						
30						
31						

Total N's

0

(NO = N = Excursions)

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

DISTRIBUTION	
<<Have Minimums been met for this day?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 2px;">0 0 9 5 3</span> <b>System Name:</b> City of Willamina <b>Sample Period:</b> Feb-25 <b>Sample Frequency:</b> Every 3 Years <b>Number of Distribution Samples Required:</b> 2

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

### Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name:

Signature:

Date:

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

ID: 4100953

Enter sample ID info in the table >>

**Sign:**

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

[illegible]