

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Date | Location | P.h. | Temp | Alk | Cl2 | Y/N |
|------|--------------|------|-------|-----|------|-----|
| 1 | 360 maple | 7.89 | 13.8 | | 0.98 | y |
| 2 | 360 maple | 7.91 | 14 | | 0.97 | y |
| 3 | 481 3rd | 7.70 | 13.8 | | 0.96 | y |
| 4 | 710 5th | 7.80 | 14.6 | | 0.98 | y |
| 5 | 391 yamhill | 7.80 | 112.6 | | 1.11 | y |
| 6 | 945 hill | 7.79 | 16.6 | 31 | 0.89 | y |
| 7 | 582 fir | 7.81 | 13.1 | | 0.89 | y |
| 8 | 500 adams | 7.90 | 11.5 | | 0.91 | y |
| 9 | 360 maple | 8.10 | 11.5 | | 1.03 | y |
| 10 | 411 c | 7.82 | 11.8 | | 0.99 | y |
| 11 | 710 5th | 7.68 | 12.5 | | 1.06 | y |
| 12 | 481 3rd | 7.62 | 14.6 | 35 | 1.01 | y |
| 13 | 500 adams | 7.71 | 13.3 | | 1.02 | y |
| 14 | 391 yamhill | 7.74 | 13.9 | | 0.87 | y |
| 15 | 360 maple | 7.95 | 13.2 | | 0.94 | y |
| 16 | 360 maple | 7.98 | 13.8 | | 0.96 | y |
| 17 | 1523 pioneer | 7.60 | 12.7 | | 0.91 | y |
| 18 | 411 c | 7.60 | 12.2 | | 1.1 | y |
| 19 | 500 adams | 7.81 | 11.2 | | 1.15 | y |
| 20 | 945 hill | 7.66 | 13.1 | 32 | 1.1 | y |
| 21 | 582 fir | 7.69 | 10.9 | | 1.09 | y |
| 22 | 500 adams | 7.7 | 13.3 | | 1.11 | y |
| 23 | 360 maple | 7.82 | 13.4 | | 1.01 | y |
| 24 | 500 adams | 7.85 | 15.6 | | 1.08 | y |
| 25 | 411 c | 7.58 | 16.8 | | 1.14 | y |
| 26 | 710 5th | 7.58 | 15.9 | | 1.2 | y |
| 27 | 481 3rd | 7.61 | 16.1 | | 1.23 | y |
| 28 | 391 yamhill | 7.66 | 13.2 | 31 | 1.16 | y |
| 29 | 360 maple | 7.71 | 13.1 | | 0.94 | y |
| 30 | 360 maple | 7.76 | 13.3 | | 0.96 | y |
| 31 | 115 ne main | 7.72 | 13.4 | | 1.07 | y |

Total N's

0

(NO = N = Excursions)

| | |
|---|--|
| DISTRIBUTION | |
| <<Have Minimums been met for this day? | PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: _____ Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2 |

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

| | |
|-------|------------------|
| pH | 7.2 |
| Alk | 30 (Alkalinity) |
| PO4 | (Orthophosphate) |
| Other | () |

Print Name:

Signature:

Date:

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

| Sample ID | Sample Location Description |
|-----------|---|
| 1 | coliform sample sites used for rotation |
| | |
| | |
| | |
| | |

Page 1 of 5