

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	481 3rd	7.70	16.3		0.92	y
2	391 yamhill	7.77	18.2		0.88	y
3	500 adams	8.14	14.8		0.83	y
4	500 adams	7.78	14.5		0.83	y
5	115 ne main	7.30	17.6		0.54	y
6	360 maple	8.01	13.9		0.85	y
7	1523 pioneer	7.71	15.2	36	0.8	y
8	945 hill	7.76	16.9		0.47	y
9	582 fir	7.82	18.9		0.77	y
10	360 maple	7.89	17.3		0.7	y
11	360 maple	7.99	16.6		0.76	y
12	500 adams	7.80	21.6		0.56	y
13	411 c	7.67	18.2		0.86	y
14	710 5th	8.02	16.8	41	0.79	y
15	481 3rd	7.80	17.3		0.93	y
16	500 adams	7.90	17.5		1.04	y
17	360 maple	7.90	17.4		0.85	y
18	360 maple	7.92	17.9		0.84	y
19	411 c	7.70	18.5		1.02	y
20	500 adams	7.9	18.6		1.04	y
21	710 5th	7.74	16.4	45	0.91	y
22	481 3rd	7.75	16.2		1.06	y
23	500 adams	7.79	18.5		0.74	y
24	360 maple	7.81	20.6		0.81	y
25	360 maple	7.79	21.2		0.78	y
26	360 maple	7.75	20		0.85	y
27	945 hill	7.81	21.6		0.9	y
28	582 fir	7.71	18.5		0.71	y
29	500 adams	7.69	18.5	45	0.81	y
30	481 3rd	7.76	20.8		0.83	y
31	360 maple	8.15	16.1		0.89	y

Total N's

0

(NO = N = Excursions)

<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">0</span> <span style="border: 1px solid black; padding: 0 5px;">9</span> <span style="border: 1px solid black; padding: 0 5px;">5</span> <span style="border: 1px solid black; padding: 0 5px;">3</span> <b>System Name:</b> City of Willamina <b>Sample Period:</b> _____ <b>Sample Frequency:</b> Every 3 Years <b>Number of Distribution Samples Required:</b> 2

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

### Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name:

Signature:

Date:

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

**Sign:**

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Page 1 of 5