

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.92	17.1		0.87	y
2	360 maple	7.88	18.3		0.76	y
3	411 c	7.63	22.2		0.99	y
4	481 3rd	7.79	19.7		1.13	y
5	710 5th	7.82	18.2		0.83	y
6	391 yamhill	7.99	18.8	43	1.02	y
7	360 maple	7.88	22		0.89	y
8	360 maple	7.86	21.8		0.91	y
9	115 ne main	7.81	22.1		1.03	y
10	1523 pioneer	7.74	19.9		0.98	y
11	945 hill	7.71	20.5		1.03	y
12	582 fir	7.75	20.4		0.91	y
13	360 maple	7.78	19.1	45	0.82	y
14	360 maple	7.96	18.2		0.9	y
15	360 maple	7.99	17.9		0.81	y
16	500 adams	7.78	21.1		1.11	y
17	411 c	7.66	23.6		0.54	y
18	710 5th	7.75	19.6	46	0.99	y
19	360 maple	7.85	18.5		0.82	y
20	481 3rd	7.65	19.5		1.05	y
21	360 maple	7.81	18.5		0.8	y
22	360 maple	7.85	19.1		0.81	y
23	360 maple	7.91	20.5		0.83	y
24	500 adams	7.76	20.8		0.99	y
25	411 c	7.75	21.5	44	0.84	y
26	710 5th	7.75	21.5		0.83	y
27	115 ne main	7.65	19.5		0.9	y
28	360 maple	8	19		0.8	y
29	500 adams	7.83	20		0.94	y
30	360 maple	7.94	21.8		0.83	y
31						

Total N's

0

(NO = N = Excursions)

DISTRIBUTION

<<Have

Minimums

been met for
this day?

PWS ID:

41

0 0 9 5 3

System Name:

City of Willamina

Sample Period:

Jun-25

Sample Frequency:

Every 3 Years

Number of Distribution Samples Required:

2

Number of excursions during this sample period:

0

(Count the number of locations when any WQP
was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample
period.

For OHA use only

**Minimum Water Quality
Parameters as set by OHA**

pH

7.2

Alk

30

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name:

Signature:

Date:

*Entry point monitoring must be done at a minimum of
once every two weeks, however, this form
may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

