

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.86	22	50	0.57	y
2	411 c	7.70	22.3	50	0.89	y
3	582 fir	7.76	23.3	52	0.71	y
4	481 3rd	7.76	22.2	52	0.85	y
5	500 adams	7.82	24.2		0.47	y
6	360 maple	7.94	22.1		0.55	y
7	360 maple	7.98	21		0.5	y
8	481 3rd	7.68	22.4	51	0.86	y
9	391 yamhill	7.75	21.7	50	0.78	y
10	115 main	7.68	20.9	52	0.97	y
11	1523 pioneer	7.72	22.6		0.63	y
12	945 hill	7.86	22		0.85	y
13	115 ne main	7.75	23		0.79	y
14	481 3rd	7.79	22.2		0.71	y
15	360 maple	8.01	22.2		0.42	y
16	411 c	7.81	22.1		0.76	y
17	500 adams	7.75	22.8	48	0.84	y
18	391 yamhill	7.88	23		0.99	y
19	582 fir	7.76	21.3		0.63	y
20	360 maple	8.16	20.2		0.47	y
21	500 adams	7.96	20.6		0.57	y
22	1523 pioneer	7.87	18.6		0.91	y
23	481 3rd	7.79	17.7		1.29	y
24	391 yamhill	7.94	18.9	49	1.09	y
25	411 c	7.75	18.6		1.18	y
26	115 ne main	7.85	19.1		1.14	y
27	360 maple	8.18	20.3	51	0.48	y
28	360 maple	8.01	19.6		0.44	y
29	360 maple	7.91	19.9		0.92	y
30	411 c	7.67	19.2		0.69	y
31						

Total N's

0

(NO = N = Excursions)

DISTRIBUTION

<<Have

Minimums

been met for

this day?

PWS ID:

41

0 0 9 5 3

System Name:

City of Willamina

Sample Period:

Sep-25

Sample Frequency:

Every 3 Years

Number of Distribution Samples Required:

2

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name:

Signature:

Date:

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:

OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

Sign:

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to 200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation

Page 1 of 5