

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	481 3rd	7.64	18.6	47	0.79	y
2	391 yamill	7.81	18.6		0.76	y
3	115 ne main	7.78	18.7		0.87	y
4	360 maple	8.07	20.9		0.46	y
5	360 maple	8.23	17.1		0.51	y
6	1523 pioneer	7.79	19.8		0.57	y
7	945 hill dr	7.88	20.9		0.79	y
8	582 fir	7.73	19.5		0.54	y
9	360 maple	8.07	18.7		0.35	y
10	500 adams	7.84	16.7		0.75	y
11	360 maple	8.09	20.2	53	0.35	y
12	360 maple	8.03	20		0.41	y
13	360 maple	7.98	19.5		0.39	y
14	411 c	7.78	19.7		0.79	y
15	391 yamill	7.81	17.8		0.84	y
16	115 main	7.54	16.3	46	0.85	y
17	582 fir	7.71	17.3		0.56	y
18	360 maple	8.11	15.9		0.26	y
19	500 adams	7.80	19		0.51	y
20	500 adams	7.89	18.9		0.76	y
21	411 c	7.71	18.7		0.79	y
22	500 adams	7.78	17.5		0.77	y
23	481 3rd	7.69	16.5	47	0.85	y
24	500 adams	7.83	17.7		0.84	y
25	360 maple	7.75	16.5		0.56	y
26	360 maple	8.05	17.6		0.44	y
27	391 yamill	7.71	16.9		0.88	y
28	115 main	7.61	14.4		0.93	y
29	1523 pioneer	7.67	17.2	38	0.75	y
30	945 hill dr	7.66	19.3		0.54	y
31	411 c	7.77	14.1		0.89	y

Total N's

0

(NO = N = Excursions)

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

DISTRIBUTION						
<<Have Minimums been met for this day?		PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Oct-25 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2				

Number of excursions during this sample period:

0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: *Justin R. Biggs*
 Signature: *Justin R. Biggs*
 Date: *11/13/25*

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Water System Name

City of Willamina

ID: 4100953

Enter sample ID info in the table >>

Sign:

Max Chlorine Residual Allowed = 4.0 mg/l Enter up to
200 results below

Sample ID	Sample Location Description
1	coliform sample sites used for rotation