

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	8.07	18.4		0.44	y
2	360 maple	8.14	15.1		0.46	y
3	582 fir	7.76	16.4		0.71	y
4	360 maple	7.97	17.1		0.42	y
5	500 adams	7.90	15.5	37	0.97	y
6	411 c street	7.65	14.8		1.01	y
7	115 main	7.70	15		0.97	y
8	360 maple	7.95	16.8		0.42	y
9	360 maple	7.98	17.1		0.41	y
10	945 hill	7.72	16.8		0.95	y
11	360 maple	8.16	15.8	34	0.44	y
12	500 adams	7.77	14.7		0.99	y
13	411 c street	7.83	14		1.03	y
14	360 maple	8.27	14.8		0.48	y
15	500 adams	7.91	16.1		0.98	y
16	500 adams	7.89	15.6		0.98	y
17	411 c street	7.55	14.1		1.08	y
18	360 maple	8.13	13.8		0.56	y
19	500 adams	7.90	15.9		0.9	y
20	391 yamhill	7.94	15.9	37	1.07	y
21	115 ne main	7.78	14.8		0.99	y
22	360 maple	7.85	16.5		0.45	y
23	360 maple	7.97	16.6		0.4	y
24	500 adams	7.71	13.4		1	y
25	411 c street	7.62	13.1		0.99	y
26	360 maple	8.29	13.2		0.75	y
27	360 maple	8.26	15.2	35	0.77	y
28	500 adams	7.65	15.1		0.9	y
29	360 maple	8.28	15		0.79	y
30	360 maple	8.18	12.8		0.72	y
31						

Total N's 0  
(NO = N = Excursions)

<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	PWS ID: <b>41</b> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">9</span> <span style="border: 1px solid black; padding: 0 2px;">5</span> <span style="border: 1px solid black; padding: 0 2px;">3</span> System Name: <u>City of Willamina</u> Sample Period: <u>Nov-25</u> Sample Frequency: <u>Every 3 Years</u> Number of Distribution Samples Required: <u>2</u>


Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<span style="border: 1px solid black; padding: 2px 10px;">7.2</span>
Alk	<span style="border: 1px solid black; padding: 2px 10px;">30</span> (Alkalinity)
PO4	(Orthophosphate)
Other	( )

Print Name: Justin R. Riggs  
 Signature:   
 Date: 12/1/25

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:  
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

