

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	481 3rd	7.67	14.8		1.04	y
2	710 5th	7.83	16.2		0.97	y
3	391 yamhill	7.56	16		0.98	y
4	115 main	7.96	15	37	0.97	y
5	500 adams	7.85	14		1.01	y
6	360 maple	8.06	16.9		0.64	y
7	360 maple	8.01	15.4		0.65	y
8	500 adams	7.70	15.9		0.84	y
9	500 adams	7.73	15.3		0.94	y
10	500 adams	7.61	15.6		0.99	y
11	360 maple	7.86	15.3	34	0.77	y
12	411 c	7.58	13.9		1.05	y
13	500 adams	7.68	14		0.8	y
14	360 m	8.14	12.8		0.81	y
15	710 5th	7.87	15.6		1.09	y
16	481 3rd	7.87	14.3		1.02	y
17	481 3rd	7.69	13.8		1.03	y
18	391 yamhill	7.64	15.4	32	1.01	y
19	115 main	7.66	13.6		0.96	y
20	360 maple	7.85	19.3		0.86	y
21	360 maple	7.92	19.5		0.85	y
22	710 5th	7.75	14.3		0.91	y
23	481 3rd	7.63	14.5	32	1.08	y
24	582 fir	7.68	12.5		0.93	y
25	500 adams	7.82	13.2		1.13	y
26	360 maple	8.17	12.5		0.93	y
27	500 adams	7.91	13.1		1.06	y
28	500 adams	8	13.3		1	y
29	360 maple	8.03	14.6		0.82	y
30	500 adams	7.98	12.3		0.87	y
31	710 5th	7.93	13.4	37	0.78	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION

<<Have Minimums been met for this day? **PWS ID:** 41 0 0 9 5 3

System Name: City of Willamina

Sample Period: Dec-25

Sample Frequency: Every 3 Years

Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by OHA

pH	7.2	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Justin R. Robbins
Signature:
Date: 1/5/25

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

