

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	8.07	13.2		0.72	y
2	360 maple	8.03	12.9		0.71	y
3	360 maple	8.15	13.5		0.73	y
4	360 maple	8.26	13.6		0.73	y
5	500 adams	7.83	14.5		0.8	y
6	945 hill	7.69	14.1		0.74	y
7	582 fir	7.74	14.3	34	0.77	y
8	500 adams	7.81	13.2		0.88	y
9	411 c	7.65	12.9		0.9	y
10	360 maple	8.15	11.9		1.19	y
11	500 adams	7.62	13.5		1.13	y
12	710 5th	7.65	14.8		1.08	y
13	411 c	7.51	13.8		1.11	y
14	481 3rd	7.57	12.9		1.08	y
15	391 yamhill	7.72	13.8	31	1.15	y
16	115 ne main	7.86	13.3		1.17	y
17	360 maple	7.91	13.5		0.97	y
18	360 maple	7.85	12.6		0.96	y
19	360 mnapple	7.83	10.9		0.87	y
20	500 adams	7.72	14.7		0.89	y
21	481 3rd	7.63	13		0.92	y
22	710 5th	7.68	12.7		0.63	y
23	115 main	7.74	11.2	33	0.78	y
24	500 adams	7.79	10.5		0.92	y
25	500 adams	7.86	10.2		1.08	y
26	582 fir	7.73	12.8		0.94	y
27	391 yamhill	7.65	10.2		0.94	y
28	115 main	7.67	10.4		0.93	y
29	500 adams	7.85	11.8	38	0.94	y
30	411 c	7.68	15.6		1.02	y
31	360 maple	7.94	14.2		0.95	y

Total N's 0  
(NO = N = Excursions)


<b>DISTRIBUTION</b>	
<<Have Minimums been met for this day?	<b>PWS ID:</b> 41 <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">0</span> <span style="border: 1px solid black; padding: 0 2px;">9</span> <span style="border: 1px solid black; padding: 0 2px;">5</span> <span style="border: 1px solid black; padding: 0 2px;">3</span> <b>System Name:</b> City of Willamina <b>Sample Period:</b> Jan-26 <b>Sample Frequency:</b> Every 3 Years <b>Number of Distribution Samples Required:</b> <span style="border: 1px solid black; padding: 0 10px;">2</span>

Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.  
Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
<b>Minimum Water Quality Parameters as set by OHA</b>	
pH	<span style="border: 1px solid black; padding: 2px 10px;">7.2</span>
Alk	<span style="border: 1px solid black; padding: 2px 10px;">30</span> (Alkalinity)
PO4	(Orthophosphate)
Other	( )

**Print Name:** Justin R Riggs  
**Signature:**   
**Date:** 2/2/06

\*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:  
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

