

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	360 maple	7.67	14.3		0.92	y
2	500 adams	7.61	15.9		0.91	y
3	710 5th	7.66	18.3		0.77	y
4	391 yamhill	7.63	14	32	0.9	y
5	115 main	7.76	14.5		0.92	y
6	945 hill	7.83	13.9		1.01	y
7	360 maple	7.88	12.8		0.98	y
8	500 adams	8.01	12.4		1.08	y
9	500 adams	8.03	15.9		1.02	y
10	411 c	7.70	16.1		1.02	y
11	710 5th	7.84	14.3	36	0.95	y
12	391 yamhill	7.83	13.1		0.83	y
13	115 main	7.59	15.1		0.78	y
14	360 maple	7.59	14.5		0.91	y
15	360 maple	7.61	14.8		0.95	y
16	500 adams	7.60	14.9		1.07	y
17	710 5th	7.88	16.4		0.88	y
18	115 main	7.86	15.9	33	1.09	y
19	945 hill	7.90	16.4		0.88	y
20	1523 pioneer	7.8	15.9		0.93	y
21	360 maple	8.02	12.8		0.96	y
22	500 adams	7.99	13.9		0.92	y
23	582 fir	7.9	14.4		0.87	y
24	500 adams	7.95	17.4		0.97	y
25	411 c	7.68	15.7	38	0.94	y
26	710 5th	7.7	14.9		0.98	y
27	481 3rd	7.71	13.6		0.86	y
28	360 maple	7.9	14.3		0.91	y
29	360 maple	7.93	14.8		0.92	y
30	391 yamhill	7.72	14.2		0.91	y
31	115 main	7.73	13.5		0.78	y

Total N's 0
(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Mar-26 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2

Number of excursions during this sample period: 0
(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.
Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R Riggs
 Signature: *Justin R Riggs*
 Date: 7/1/26

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

