

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	Location	P.h.	Temp	Alk	Cl2	Y/N
1	500 adams	7.84	15.7		0.88	y
2	945 hill	7.76	13.5		0.82	y
3	500 adams	7.70	13.1		0.89	y
4	500 adams	7.83	15.5		0.99	y
5	360 maple	8.01	13		0.83	y
6	945 hill	7.73	10.9		0.91	y
7	582 fir	7.75	14.1		0.9	y
8	582 fir	7.79	14.3	38	0.93	y
9	360 maple	7.90	14.3		0.74	y
10	710 5th	7.90	16.6		1	y
11	360 maple	7.94	13.2		0.95	y
12	360 maple	7.99	13.9		0.93	y
13	411 c	7.70	14.8		0.99	y
14	500 adams	7.67	15.2		0.97	y
15	1523 pioneer	7.73	18.1		1.07	y
16	945 hill	7.62	16.8		0.99	y
17	582 fir	7.76	18.4	36	1.02	y
18	500 adams	7.58	15.2		1.13	y
19	360 maple	7.91	14		0.98	y
20	411 c	7.67	16.5		0.96	y
21	481 3rd	7.68	16.1		0.9	y
22	710 5th	7.79	20.8		0.98	y
23	391 yamhill	7.74	17.5		0.85	y
24	115 main	7.55	16.3	37	0.43	y
25	360 maple	7.85	16.5		0.92	y
26	360 maple	7.86	17		0.95	y
27	411 c	7.63	18.8		0.76	y
28	500 adams	7.66	13.8		1.09	y
29	500 adams	7.61	14.3		1.07	y
30	710 5th	7.65	18.9	36	0.82	y
31						

Total N's 0

(NO = N = Excursions)

DISTRIBUTION	
<<Have Minimums been met for this day?	PWS ID: 41 0 0 9 5 3 System Name: City of Willamina Sample Period: Apr-26 Sample Frequency: Every 3 Years Number of Distribution Samples Required: 2


Number of excursions during this sample period: 0

(Count the number of locations when any WQP was less than the minimum required)

Note: Entry Point and Distribution Excursions are cumulative.

Add Entry Point and Distribution Excursions to get total for sample period.

<i>For OHA use only</i>	
Minimum Water Quality Parameters as set by OHA	
pH	7.2
Alk	30 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Justin R. Riggs
 Signature: 
 Date: 5/1/26

*Entry point monitoring must be done at a minimum of once every two weeks, however, this form may be used for more frequent sampling.

Send to DWS within 10 days after end of the sampling period to:
 OHA-Drinking Water Services, PO Box 14350, Portland, Or 97293-0350 Phone (971) 673-0405

