

Lead & Copper Rule Corrosion Control



Day	pH	Alk	Phos	Other	Y/N
1	7.4				N
2	7.3				N
3	7.4				N
4	7.3				N
5	7.3				N
6	7.3				N
7	7.1				N
8	7.2				N
9	7.3				N
10	7.3				N
11	7.4				N
12	7.4				N
13	7.5				N
14	7.3				N
15	7.5				N
16	7.2				N
17	7.4				N
18	7.4				N
19	7.4				N
20	7.4				N
21	7.3				N
22	7.4				N
23	7.3				N
24	7.0				N
25	7.3				N
26	7.3				N
27	7.5				N
28	7.4				N
29	7.3				N
30	7.3				N
31	7.3				N
No = N = Excursion) Total N's					0



Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation.

EntryPoint and Distribution excursions are cumulative)

Print Name: Rick McClung

Signature: _____

Date: 4/10/2021

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>