

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.5				Y
4	7.5				Y
5	7.6				Y
6	7.4				Y
7	7.7				Y
8	7.2				Y
9	7.5				Y
10	7.5				Y
11	7.8				Y
12	7.4				Y
13	7.4				Y
14	7.5				Y
15	7.4				Y
16	7.3				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.5				Y
25	7.3				Y
26	7.5				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: June 2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Rick McClung

Signature: Rick McClung

Date: 7/8/21

Send to DWP within 10 days after end of sampling period