

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	//N	< <have entry="" minimums="" point<="" th=""></have>
1	7.3				Y	THE HITCH IS
2	7.4				V	been met for this day? PWS ID: 41 00966
3	7.4				4	
4	73				Y	System Name: City of iacharts
5	7,2				Y	Entry Point: E 2 & Prospect
6	7.3				Y	Sample Period: Sept 2021
7	7.3				Y	Month/Year
8	73				<u>y</u>	Number of excursions* during this month:
9	74			1	Y	(Count the number of days when any WQP was
10	7.3				Y	less than the minimum required)
11	74				7	
12	7.4				У	Total excursions during the previous 5 months:
13	7.5				Y	(Over 9 excursions in 6 months is a violation. Entry
14	7.4				7	Point and Distribution excursions are cumulative)
15	7.4				_	For OHA use only
16	7,4				7,	
17	1,4				7	Minimum Water Quality
18	7.4				7	Parameters as set by
19	7.5				X	pH 7.0
20	7:4				X.	Alk / (Alkalinity)
21	7,4				7,	PO4 (Orthophosphate)
22	7.5				7	Other ()
23	7.6				7	
24	1-5				7	
25 26	7,5				y	
27	7.4				7	O-VMCMI
	7.3				7	Print Name:
28	7.6				7	Signature:
30	716				7	Date:
31	7.6				4	Send to DWP within 10 days after end of
	-	ureior	n) Tota	I N's	62	sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/