



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.3				Y
7	7.3				Y
8	7.4				Y
9	7.4				Y
10	8.2				Y
11	8.2				Y
12	8.2				Y
13	8.2				Y
14	7.6				Y
15	7.4				Y
16	7.4				Y
17	7.2				Y
18	7.4				Y
19	7.2				Y
20	7.3				Y
21	7.4				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.5				Y
31	7.1				Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: E. 2<sup>nd</sup> & Prospect

Entry Point: City of Yachats

Sample Period: Dec. 2021  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other

Print Name: Rick McClung

Signature: R. McClung

Date: 1/10/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's