

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.4				Y
3	7.4				Y
4	7.2				Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.4				Y
9	7.4				Y
10	7.4				Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.5				Y
16	7.5				Y
17	7.2				Y
18	7.3				Y
19	7.5				Y
20	7.6				Y
21	7.6				Y
22	7.3				Y
23	7.3				Y
24	7.6				Y
25	7.6				Y
26	7.8				Y
27	7.6				Y
28	7.3				Y
29	7.4				Y
30	7.5				Y
31	7.4				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: NOV 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Rick McCung

Signature: [Signature]

Date: 12/1/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's