

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.4				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.1				Y
8	7.2				Y
9	7.3				Y
10	7.3				Y
11	7.4				Y
12	7.4				Y
13	7.5				Y
14	7.3				Y
15	7.5				Y
16	7.2				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.3				Y
22	7.4				Y
23	7.3				Y
24	7.0				Y
25	7.3				Y
26	7.3				Y
27	7.5				Y
28	7.4				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yachats

Entry Point: E, 2nd & Prospect

Sample Period: March 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Rich McClung

Signature: R. McClung

Date: 4/10/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's