

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.00				y
2	7.00				y
3	7.20				y
4	7.20				y
5	7.20				y
6	7.20				y
7	7.20				y
8	7.20				y
9	7.20				y
10	7.10				y
11	7.10				y
12	7.10				y
13	7.20				y
14	7.20				y
15	7.20				y
16	7.30				y
17	7.30				y
18	7.30				y
19	7.30				y
20	7.10				y
21	7.10				y
22	7.30				y
23	7.30				y
24	7.20				y
25	7.20				y
26	7.20				y
27	7.20				y
28	7.20				y
29	7.20				y
30	7.20				y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00966

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: June 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Rick McClung

Signature: Glen R. McClung

Date: 7/10/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0