

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.1				y
2	7.1				y
3	7				y
4	7.1				y
5	7.2				y
6	7.2				y
7	7.4				y
8	7.3				y
9	7.3				y
10	7.3				y
11	7.4				y
12	7.3				y
13	7.2				y
14	7.1				y
15	7.1				y
16	7.3				y
17	7.1				y
18	7.2				y
19	7.2				y
20	7.2				y
21	7.1				y
22	7.4				y
23	7.4				y
24	7.3				y
25	7.3				y
26	7.3				y
27	7.2				y
28	7.3				y
29	7.3				y
30	7.2				y
31	7.20				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 00966

**System Name:** City of Yachats

**Entry Point:** E. 2nd & Prospect

**Sample Period:** July 2023  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

**Print Name:** Rick McClung

**Signature:** Glen R. McClung

**Date:** 8/8/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0