

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				y
2	7.3				y
3	7.2				y
4	7.4				y
5	7.3				y
6	7.5				y
7	7.4				y
8	7.4				y
9	7.3				y
10	7.3				y
11	7.3				y
12	7.3				y
13	7.3				y
14	7.5				y
15	7.3				y
16	7.4				y
17	7.4				y
18	7.5				y
19	7.3				y
20	7.5				y
21	7.4				y
22	7.4				y
23	7.3				y
24	7.3				y
25	7.2				y
26	7.3				y
27	7.2				y
28	7.2				y
29	7.3				y
30	7.3				y
31	7.3				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **00966**

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: August 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Rick McClung

Signature: Glen R. McClung

Date: 9/6/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **0**