

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 7.4 | | | | y |
| 2 | 7.4 | | | | y |
| 3 | 7.4 | | | | y |
| 4 | 7.5 | | | | y |
| 5 | 7.3 | | | | y |
| 6 | 7.6 | | | | y |
| 7 | 7.4 | | | | y |
| 8 | 7.2 | | | | y |
| 9 | 7.3 | | | | y |
| 10 | 7.3 | | | | y |
| 11 | 7.3 | | | | y |
| 12 | 7.3 | | | | y |
| 13 | 7.4 | | | | y |
| 14 | 7.3 | | | | y |
| 15 | 7.4 | | | | y |
| 16 | 7.4 | | | | y |
| 17 | 7.3 | | | | y |
| 18 | 7.3 | | | | y |
| 19 | 7.4 | | | | y |
| 20 | 7.6 | | | | y |
| 21 | 7.1 | | | | y |
| 22 | 7.3 | | | | y |
| 23 | 7.3 | | | | y |
| 24 | 7.3 | | | | y |
| 25 | 7.3 | | | | y |
| 26 | 7.3 | | | | y |
| 27 | 7.3 | | | | y |
| 28 | 7.2 | | | | y |
| 29 | 7.1 | | | | y |
| 30 | 7.1 | | | | y |
| 31 | 7.50 | | | | |

(No = N = Excursion) **Total N's** 0

<<Have

minimums

been met for

this day?

ENTRY POINT

PWS ID: 41

00966
System Name: City of Yachats
Entry Point: E. 2nd & Prospect
Sample Period: Oct 2023
Month/Year
Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)
Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*
Print Name: Rick McClung
Signature: Glen R. McClung
Date: 11/8/2023

Send to DWP within 10 days after end of sampling period