



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.1				Y
2	7.2				Y
3	7.3				Y
4	7.4				Y
5	7.4				Y
6	7.2				Y
7	7.4				Y
8	7.3				Y
9	7.4				Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.7				Y
15	7.6				Y
16	7.6				Y
17	7.5				Y
18	7.5				Y
19	7.4				Y
20	7.3				Y
21	7.2				Y
22	7.4				Y
23	7.5				Y
24	7.4				Y
25	7.6				Y
26	7.4				Y
27	7.8				Y
28	7.4				Y
29	7.3				Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00966

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: Feb 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	/	(Alkalinity)
PO4	/	(Orthophosphate)
Other		()

Print Name: Rick McClung

Signature: R. McClung

Date: 3/10/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>