

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.6				Y
3	7.5				Y
4	7.6				Y
5	7.6				Y
6	7.4				Y
7	7.4				Y
8	7.3				Y
9	7.5				Y
10	7.7				Y
11	7.6				Y
12	7.6				Y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.7				Y
18	7.7				Y
19	7.7				Y
20	7.4				Y
21	7.3				Y
22	7.4				Y
23	7.8				Y
24	7.7				Y
25	7.7				Y
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.7				Y
31	7.8				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: MAY 2024
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="/"/>	(Alkalinity)
PO4	<input type="text" value="/"/>	(Orthophosphate)
Other	<input type="text" value="/"/>	(_____)

Print Name: Rick McClung

Signature: 6/10/24 R. McClung

Date: 6/10/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's