

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.4 |     |      |       | Y   |
| 2   | 7.0 |     |      |       | Y   |
| 3   | 7.1 |     |      |       | Y   |
| 4   | 7.3 |     |      |       | Y   |
| 5   | 7.3 |     |      |       | Y   |
| 6   | 7.3 |     |      |       | Y   |
| 7   | 7.4 |     |      |       | Y   |
| 8   | 7.0 |     |      |       | Y   |
| 9   | 7.0 |     |      |       | Y   |
| 10  | 7.6 |     |      |       | Y   |
| 11  | 7.4 |     |      |       | Y   |
| 12  | 7.6 |     |      |       | Y   |
| 13  | 7.6 |     |      |       | Y   |
| 14  | 7.5 |     |      |       | Y   |
| 15  | 7.4 |     |      |       | Y   |
| 16  | 7.4 |     |      |       | Y   |
| 17  | 7.4 |     |      |       | Y   |
| 18  | 7.5 |     |      |       | Y   |
| 19  | 7.5 |     |      |       | Y   |
| 20  | 7.4 |     |      |       | Y   |
| 21  | 7.6 |     |      |       | Y   |
| 22  | 7.3 |     |      |       | Y   |
| 23  | 7.4 |     |      |       | Y   |
| 24  | 7.4 |     |      |       | Y   |
| 25  | 7.4 |     |      |       | Y   |
| 26  | 7.4 |     |      |       | Y   |
| 27  | 7.5 |     |      |       | Y   |
| 28  | 7.5 |     |      |       | Y   |
| 29  | 7.1 |     |      |       | Y   |
| 30  | 7.2 |     |      |       | Y   |
| 31  | 7.1 |     |      |       | Y   |

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00966

System Name: City of Yachats

Entry Point: E. 2nd & Prospect

Sample Period: July 2024  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.0

Alk / (Alkalinity)

PO4 / (Orthophosphate)

Other / (\_\_\_\_\_)

Print Name: Rick McLaughlin

Signature: [Signature]

Date: 8/7/24

Send to DWP within 10 days after end of sampling period