

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.3				Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.2				X
9	7.2				Y
10	7.2				Y
11	7.2				Y
12	7.2				Y
13	7.3				Y
14	7.2				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.3				Y
24	7.3				X
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00966

System Name:

City of Yachats

Entry Point:

E. 2nd & Prospect

Sample Period:

January 2025

Month/Year

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.0

Alk

/

(Alkalinity)

PO4

/

(Orthophosphate)

Other

/

()

Print Name:

Rick McClung

Signature:

R. McClung

Date:

2/10/25

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>