

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				✓
2	7.2				✓
3	7.2				✓
4	7.1				✓
5	7.2				✓
6	7.1				✓
7	7.1				✓
8	7.2				✓
9	7.2				✓
10	7.2				✓
11	7.2				✓
12	7.2				✓
13	7.1				✓
14	7.1				✓
15	7.4				✓
16	7.4				✓
17	7.4				✓
18	7.4				✓
19	7.3				✓
20	7.2				✓
21	7.2				✓
22	7.1				✓
23	7.2				✓
24	7.3				✓
25	7.3				✓
26	7.1				✓
27	7.1				✓
28	7.0				✓
29	7.1				✓
30	7.2				✓
31	7.1				✓

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00966

System Name: City of Yachats

Entry Point: E. 2nd St. + Prospect Ave.

Sample Period: March 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
Alk 100 (Alkalinity)
PO4 0.1 (Orthophosphate)
Other ()

Print Name: David Buckwald

Signature: David Buckwald

Date: 4-8-25

Send to DWP within 10 days after end of
sampling period