

Lead & Copper Rule Corrosion Control

APRIL 2025

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.8				Y
3	7.8				Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.1				Y
9	7.2				Y
10	7.2				Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.1				Y
23	7.2				Y
24	7.2				Y
25	7.3				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.2				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00966

System Name: City of Yachats

Entry Point: E. 2nd + Prospect Ave.

Sample Period: April 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: David Buckwald

Signature: David Buckwald

Date: 5-8-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0