

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.1				Y
3	6.9				X
4	7.2				Y
5	7.2				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.2				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.2				X
18	7.3				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.1				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.3				Y
30	7.2				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00966

System Name: City of Yachats

Entry Point: E. 2nd + Prospect Ave.

Sample Period: June 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)
Alk
PO4 (Orthophosphate)
Other ()

Print Name: David Buckwald

Signature: David Buckwald

Date: 7-7-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0